



Sanitary Sewer Overflow Annual Report

Division of Surface Water

Date: 03/07/2017

Facility Name: Amherst WPCC

Ohio NPDES Permit Number: 3PD00001*LD

Period Covered by Report: 01/01/2016 - 12/31/2016

Contact Person

Name: Alan Brailer

Title: Superintendent

Mailing Address: 931 North Lake Street

City: Amherst

State: OH

Zip Code: 44001

Country: USA

Sanitary Sewer Overflows Spreadsheet(attachment) : 2016SSOOverflow.xlsm

Water In Basement Occurrences Spreadsheet(attachment) : 2016AnnualWIBOccurrences.xlsm

Narrative analysis of WIB patterns by location, frequency and cause: *For the year encompassing 2016 there was only one of our four sewershed areas that experienced a WIB. That area, the siphon chamber area, had one non owner responsible reported WIB. This event was caused by an improperly installed utility pole.*

Additional Attachments :

Certification

I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately responsible for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.

Name:

Alan J Brailer

Title:

Superintendent

Signature(Electronically submitted by):

Alan J Brailer (User ID: abrailer)

Submission Date:

03/07/2017